



Generated file by QChecklists  
<https://www.quollnet.com>

# Accessibility Feature Installation Inspection Checklist

Interactive checklist for inspecting accessibility features like ramps, elevators, and signage. Commentable and exportable as PDF/Excel with QR code verification.

Project:

Date:

Filled by:

## Ramp Installation

1	Check the slope of the ramp is within the acceptable range (1:12) to ensure safe access.
2	Verify the width of the ramp is at least 36 inches to accommodate wheelchairs.
3	Ensure the ramp surface is non-slip and free of obstructions.

## Elevator Accessibility

4	Check that elevator buttons are at an accessible height (between 15 and 48 inches).
5	Verify that the elevator provides audible floor indicators for visually impaired users.
6	Ensure the elevator door remains open for adequate time (minimum 3 seconds) to allow entry and exit.

## Signage Inspection

7	Ensure all accessibility signs are clearly visible and positioned at appropriate heights.
8	Verify that tactile signs are available for visually impaired users.
9	Check that directional signs lead clearly to accessible routes and facilities.

## Handrail Installation

10	Verify handrails are installed on both sides of stairs and ramps where required.
11	Check that handrails are at a height of 34 to 38 inches from the ramp or stair surface.
12	Ensure handrails extend at least 12 inches beyond the top and bottom of the ramp or stairs.

## Door Accessibility

13	Check that door widths are at least 32 inches wide to accommodate wheelchairs.
14	Ensure doors are equipped with automatic or easy-to-use handles and openers.
15	Verify that door thresholds are no more than 1/2 inch high to prevent tripping hazards.

Comments:

Filled by:

Signature:

Introduction	How to use this checklist
Inspecting accessibility feature installations is a crucial process to ensure that buildings and public spaces comply with accessibility standards and provide safe and inclusive environments for all individuals. This checklist covers the inspection of various accessibility features like ramps, elevators, signage, and handrails, ensuring they are installed correctly and function as intended. Proper inspection helps avoid potential legal issues, improves safety and comfort for users, and maintains the overall integrity of the facility. Users can interact with this checklist online, add comments, and export their findings as a PDF or Excel file, complete with a QR code for verification.	1. Click the 'Use this checklist' or 'Start Interactive Checklist' button to launch interactive mode. 2. Tick each item online as you complete it. 3. Add comments on individual items or the entire checklist. 4. Click 'Share' or 'Download' to download your completed checklist as PDF or Excel.